
сат. No. 5366-HGAN NEMA 5-20P ANGLE PLUG, CLEAR "SEE THROUGH" COVER, HOSPITAL GRADE, 2 POLE 3 WIRE GROUNDING, 20 AMPERE 125 VOLT

APPROVALS / CERT'S. CSA 🗹 UL 🗹 UL/FS 🗹


ALL DIMENSIONS ARE IN MILLIMETERS

MAXIMUM JACKET O.D. ACCEPTED BY INTERNAL STRAIN RELIEF = 12.5 DIA (0.500") MAXIMUM CONDUCTOR SIZE ACCEPTED BY TERMINALS = 4.0 (12 AWG)

CORDAGE PREPARATION			
CONDUCTOR INSULATION COLOR	CONDUCTOR	"LENGTH"	"STRIP"
GREEN / YELLOW	GROUND	32	12.5
BLUE	NEUTRAL	19	12.5
BROWN	LINE	38	12.5



CORDAGE PREPARATION



International Configurations, Inc. P.O. Box 3374 Enfield, Connecticut 06083 TEL (860) 749-6380 FAX (860) 749-2985